

RADIO CORPORATION OF AMERICA RCA VICTOR DIVISION PR 2W68 PAR DATE May 14, 153 PAGE TUBE DEPT. STANDARDIZING

HARRISON, N. J. LANCASTER, PA.

MANDREL - By Annealing in Hydrogen

STANDARDIZING NOTICE

1955

34-14-38C

SUPERSEDED DATE

7/19/46

Supersedes former 14-3-12, p. 1

Purpose of setting coils is to hold them to the specified sizes respective of length, T.P.I. etc., and also to minimize waviness after winding.

1. EQUIPMENT

a. Hydrogen Annealing Furnace -

24" Muffle Furnace Model 780F capable of reaching temperature of 1700°C. Furnace should be equipped with a cone shaped entrance with opening of 1/4". The exit tube should be at least 12" long, x 2-1/8" diam., and have an opening of 1/4".

b. Winding Head -

For Standard 3 3/4 I.D., steel rims and capable of producing speed from 5 - 50 mts/min.

c. Unwinding Head -

To accommodate 3 3/4" I.D. steel rims.

**d. Optical Pyrometer

2. ANNEALING SCHEDULES

a.	Size (mils)	<u>Wandrel</u>	Speed (Mts./Min.)	Volts (Approx.)	Temperature (Deg.Centigrade)
	2.5-10.0	Steel	8-10	90	1050
	10-25.0	Brass	11	70	700
	3.0-10.0	Molybdenum	11	120	1400

- b. Rate of hydrogen flow should be 3-5 cu. ft./hr. (Flame length about 3/4").
- c. Temperature and speed should be sufficient to produce coils as straight and uniform in size as possible without stretching or making mandrel brittle.
- ** d. Check temperature of furnace using an optical pyrometer when furnace temperature has reached equilibrium after each setting change of the annealing furnace and before each shift's operation.

ENGINEERING SECTION STANDARDIZING

%Exit tube is not water-cooled